

**SECTION 00 9112
ADDENDUM NUMBER 02**

PARTICULARS:

DATE: January 07, 2025
 PROJECT: 2025 Roof Replacements
 PROJECT NUMBER: 2240017800
 OWNER: Southeast Polk Community School District
 ARCHITECT: Shive-Hattery, Inc.

TO: PROSPECTIVE BIDDERS:

THIS ADDENDUM FORMS A PART OF THE BIDDING AND CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED 12-09-2024, WITH AMENDMENTS AND ADDITIONS NOTED BELOW. THIS ADDENDUM SUPERSEDES AND SUPPLEMENTS ALL PORTIONS OF THE ORIGINAL BIDDING AND CONTRACT DOCUMENTS WITH WHICH IT CONFLICTS.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.


GENERAL CLARIFICATIONS

1. **Q:** Clarify attachment of roofing insulation components.

A: All insulation components should follow the following assembly from the vapor barrier up: Base layer only mechanically fastened, all other layers of insulation shall be installed utilizing low rise adhesive followed by an adhered membrane and appropriate flashings.

ATTACHMENTS: N/A

PREPARED BY: SHIVE-HATTERY, INC.

	I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.	
	<i>Karen Hardisty</i>	1/7/2025
	Signature	Date
	Printed or Typed Name	Karen E. Hardisty
	License Number	22588
My License Renewal Date is:	12-31-2026	
Pages, Sheets, or Divisions covered by this Seal: Addendum 02.		

END OF ADDENDUM NUMBER 02